



NOTES:

1. CONCRETE BENCHES MUST BE SLOPED AWAY FROM THE MANHOLE WALL BEGINNING IN LINE WITH THE TOP OF THE PIPE AND SLOPED DOWN TO THE SPRING-LINE OF THE PIPE INVERT. SLOPE TO BE $\frac{1}{2}$ " PER FT TYPICAL.
2. MAIN LINE ENTRIES TO HAVE CAST IN PLACE TROUGHS.
3. RADIUS OF INVERT MUST HAVE ENOUGH ROOM TO BE ABLE TO INSERT AIR PLUGS AND STANDARD TRACTOR TV EQUIPMENT.

STANDARD SEWER INVERT PLANS FOR MANHOLE

STANDARD PLAN:
SS - 060

DATE: **FEB. 2007**

CITY ENGINEER APPROVAL:

Longview: **C.B.**

Kelso: **S.Z.**